



Energy Policy, Climate Policy and the Electric Sector:

Understanding the challenges to wind's role in a low-carbon electric future

Victor Niemeyer
Technical Executive

EPRI GCC Research Seminar May 18, 2010

How Much Wind in a Low-Carbon Future?


- A national policy to curb CO₂ emissions below existing levels will initiate a competition to replace existing coal
- Wind resource potential is huge
 - Exceeding 50% of U.S. electric energy needs at \$80-\$90/MWh
 - Potentially exceeding current generation from coal
- Potential is substantially limited by:
 - Variability and timing
 - hours of no output over region
 - rapid hour-to-hour changes
 - Location
 - high cost of transmission






Truepower Data Reflect Realistic Meteorology, Resource Supply, and Turbine Technology

- 5,354 sites picked from 200m grid national survey
 - Exclusion areas
 - 100 MW site minimum
 - Distance to grid
 - Terrain/wake effects







- 12 year hourly simulation based on 1997-2008 meteorology for
 - 80m hub 1.5 MW turbine
 - Min/Max energy density
 - Power curves




Result: Wind Energy Supply Has Vast Potential




How the Wind Stacks Up Against New Nuclear



How the Wind Stacks Up New Gas CCs




How Wind Stacks Up Against Existing Coal



Regional Supply Curves Show Dominant Role of Great Plains (NW-Central)

National Wind Energy Supply Curves by Region



Four Challenges to Exploiting this Resource

Variability 1: hours of no output over entire region

Variability 2: rapid hour-to-hour changes

Location: high cost of transmission to load centers

Timing: anti-correlation with load

Context is adding wind in sufficient


quantities to displace bulk of U.S. CO2

emissions

"What are the limits to wind's role in a low-carbon electricity future?"



Analysis Based on Wind Data for Great Plains Represented by NW-Central Region




- Hourly wind output from 23 "bins" by state and capacity factor (i.e., ND w. 40-45% CF)
- 582 GW in 1,509 sites, avg. CF 39%
- Each bin has <u>own hourly shape</u> but bin shapes are highly correlated
- State <u>hourly load data</u> for 2007 from Energy Velocity
- Hourly loads and wind output <u>synchronized</u> so driven by same 2007 meteorology
- Scenarios vary installed wind capacity within region, ranked by capacity factor

Variability Issue 1: Output Dips to Near-zero




NW-Central Region Has Abundant Wind But Low Minimums

Regional Diversified Wind Output Duration Curves for 2007 Simulation




All Regions Experience Near-zero Minimum Wind Output Levels a Few Hours

Regional Diversified Wind Output Duration Curves for 2007 Simulation




Region-wide (7 states) Low Output Can Continue for Extended Periods

NWC Time Series from 5/5/07 to 5/12/07 w 50 GW Added




Region-wide (7 states) Low Output Can Continue for Extended Periods

NWC Time Series from 5/5/07 to 5/12/07 w 50 GW Added



Weather Chart for 5/8/2007, 1800Z (2pm EST)



Observations and Insights on Low Minimums

- Data show near-zero minimums despite aggregation of output over broad geographic regions
 - Sub-hourly minimums can only be lower
 - Minimums occur for many hours
- Will need essentially 100% back up for reliability
- Sources of backup
 - Keeping existing fossil fleet and adapting it to new operating role (fast starts, low minimums)
 - Adding new reserve capacity (new CTs?)
 - Adding electricity storage
- All of these sources of reserve services will add additional cost to using wind




Variability Issue 2: Increased Requirements for Ramping



Anti-correlation of Wind with Load Creates a Ramping Nightmare

NWC Time Series from 8/9/07 to 8/16/07 w 50 GW Added




Observations and Insights on Ramping

- Hour-to-hour wind output can vary greatly up or down
 - Greater relative changes than load
- Anti-correlation of wind with load exacerbates the problem
 - Rapid drop in output during day when loads growing
 - Rapid increase in output in evening when loads falling
- Presents a tremendous challenge to system operators trying to maintain frequency
- Imposes tremendous stress on fossil generation
- Challenge exists even with 20-20 wind forecasting
- Increased need for regulation/load-following will add to cost of using wind if significant fraction of system
 - Adapting existing fleet, new CTs, new storage?




Anti-correlation of Wind with Load Also Forces Diminishing Returns to Wind Additions: <u>50 GW</u>

NWC Time Series from 8/9/07 to 8/16/07 w 50 GW Added




Anti-correlation of Wind with Load Also Forces Diminishing Returns to Wind Additions: <u>75 GW</u>


NWC Time Series from 8/9/07 to 8/16/07 w 75 GW Added



Anti-correlation of Wind with Load Also Forces Diminishing Returns to Wind Additions: 100 GW



Economic Analysis



Cost of Electricity (COE) Working Assumptions

- Capital Cost: \$2,000/kW (onshore)
- Connection Cost*:

trans distance (km to 115kV)


- * \$138 (cost of line in \$000/km)
- + \$3,200,000 (new substation)
- Fixed Charge Rate: 0.128
- Fixed O & M: \$25/kW-year

^{*} Depends on site MW, example here representative for 100MW site




Site Capacity Factors Drive Average Costs of Generation; Distance to Grid is Secondary


Wind Generation Costs by Capacity Factor




Potential Supply Far Outstrips Region Load




Starting At 50 GW, Additions Show Diminishing Returns in Meeting Region Load



At 175 GW of Additions As Much Wind is Spilled as is Used to Serve Load



With Spills Incremental COE of <u>Delivered</u> Wind Generation Skyrockets




Observations

- NW-Central is the wind breadbasket
- Wind saturates region load starting at about 50 GW of additions (about 10% of economic resource base)
- As wind is added residual load to be met by fossil and other dispatchable power becomes highly variable
 - Rapid hour-to-hour changes due to negative correlation of wind and load increases ramping demand
 - Periods with no wind region-wide require reserves able to fully meet load
 - High value to operators in forecasting wind output
- Utilization of unused 90% of economic resource will require transmitting wind energy to other regions
- So, how does long distance transmission impact economics of wind generation delivered to meet loads in other regions?



Illustrative Transmission Costs



Assumptions and calculations

Cost of transmission: ~ \$3-5 million/mile for 800kV DC

• Losses: ~ 5%

MW transmitted: 6,400


Resulting assumed cost: \$35,000/MW-year

REGEN Analysis Provides Preliminary Realistic Assessment of Wind's Strategic Potential


- Analysis based on
 - 8,760 hourly wind resource potential based on 2007 meteorology from AWS Truepower
 - Simultaneous 2007 hourly loads from Energy Velocity
- REGEN used to estimate wind supply vs. cost per MWh for varying quantities of wind resource use
 - Include spill effects as wind surpasses dispatchable load within 12 REGEN regions
 - Include costs for new transmission to move wind energy across regions (cuts local spill)
- Result is estimate of what it costs to deliver strategic quantities of wind energy to major load centers



Existing Inter-Region Transmission Capacity




Distance and Investment Cost per Mile Drives New Transmission Costs Between Regions




Preliminary Analysis of National Wind Supply with Transmission Costs and Spillage Effects

National-Level Wind Energy Supply Curve




A Sense of the Challenges (What does it take to deliver potential wind below \$150/MWh?)

National-Level Wind Energy Supply Curve




Resulting New Transmission Investment in \$150/MWh Wind Case




How Does Transmission Cost Affect Delivered Supply?

National-Level Wind Energy Supply Curve



So What Drives Increases in Delivered Cost?





So, How Much Wind?

- Adding transmission enables greater utilization of wind
- Delivered COEs are significantly higher than generation costs
- Anti-correlation with load limits the fraction existing coal wind can displace in a decarbonized electric future